

Early History of the PDV

Ted Strand
National Securities Technologies, LLC

and

Tony Whitworth
Lawrence Livermore National Laboratory

PDV Workshop, Las Vegas, NV
June 24 – 26, 2014

This work was done by National Security Technologies, LLC,
under Contract No. DE-AC52-06NA25946
with the U.S. Department of Energy.



Nevada National Security Site

Managed and Operated by National Security Technologies, LLC



Outline

Ted's background
Tony's background

Fabry-Perot Velocimetry
Desire for alternative method

Tony discovers the circulator
Making PDV work

First real data for a paying customer

Conclusions




Nevada National Security Site

Managed and Operated by National Security Technologies, LLC



Ted's Background

1982 – 1992 X-ray measurements using
multi-mode fibers and streak cameras




Absolutely-calibrated systems

Correlate counts per pixel to x-ray output at source

Pulsed systems required accurate timing

Ted's Background

1992 – 1996 High-bandwidth opto-electronic devices coupled to single mode fibers



Collaborated with outside industry

Learned about commercially-available products

Team members worked with electronic components at many 10's of GHz

Learned about single mode fibers and components



Nevada National Security Site

Managed and Operated by National Security Technologies, LLC




Ted's Background

1996 - 2003

Fabry-Perot Velocimetry

on sub-critical experiments at NTS



Learned that some people actually care about velocities

Learned how to measure km/s velocities

Programmatic requirement for independent measurement



Nevada National Security Site

Managed and Operated by National Security Technologies, LLC



Tony's Background

- 1989-1994 Lawrence Livermore National Lab
AVLIS Program working with
Copper Vapor Lasers
- 1994-1995 Hobart Laser Systems, service engineer
multi-kilowatt CW Yag laser systems





Nevada National Security Site

Managed and Operated by National Security Technologies, LLC



Tony's Background

1995-2000 Sandia National Lab / CA
Combustion Research Facility
Particle Image Velocimetry, Laser Induced
Fluorescence, Laser Doppler Anemometry



Nevada National Security Site

Managed and Operated by National Security Technologies, LLC

National Security Technologies LLC
Vision • Service • Partnership

Tony's Background

2000-2001 Continuum Lasers
 Scientific and custom laser testing

2001-Current Lawrence Livermore National Lab

Photonic Doppler Velocimetry
Doppler Shock Arrival diagnostic
VISAR





Nevada National Security Site

Managed and Operated by National Security Technologies, LLC



Fabry-Perot Velocimetry at LLNL

Manybeam Velocimeter developed by David Goosman



Photos from: The Multibeam Fabry-Perot Velocimeter: Efficient Measurement of High Velocities, David Goosman, Science & Technology Review, July 1996




Nevada National Security Site

Managed and Operated by National Security Technologies, LLC



Manybeam Velocimeter at LLNL: beautiful but expensive



Manybeam Velocimeter

Advantages

- Carefully designed diffraction-limited optical system
- “Unlimited” maximum velocity
- Able to record multiple discrete velocities
- Able to record dispersion

Disadvantages

- Very expensive
- Many custom-built optics
- Labor intensive
- Large physical size

Ed Daykin and I spent many hours discussing how to make F-P smaller, easier, cheaper: “Fabry in a Box”



SCE requirement: a backup to FP for Accordion

Accordion was to be a big expensive test.

Fabry-Perot was to be the primary diagnostic.

The test designer wanted a fully independent
velocity measurement.

Too expensive to build a 2nd FP system

VISAR was an option, but...


Cannot handle multiple frequencies.

We set out to see what we could do by generating
and measuring a beat frequency.



Manybeam Velocimeter

Standard probe geometry



Any alternative velocimeter needed to accommodate a probe of this size and collection efficiency = $1e-4$.

Our goal was to complement the number of F-P probes with additional probes, plus provide backup.

In 1996, we were heavily invested
in the Fabry-Perot Manybeam system

We had systems at several locations

Site 300: 4 systems

HEAF: 1 system

U1a: 3 systems

BEEF: 1 system

Each analyzer table had 5 streak cameras (\$100K each)

Each laser was custom long pulse doubled YAG (\$250K each)

Etalons were \$50K to \$75K each.

It was a given that we would try to capitalize on that inventory.



Nevada National Security Site

Managed and Operated by National Security Technologies, LLC



What if we tried to measure the beat frequency?

At 1 km/s and 532 nm, the beat frequency is 3.76 GHz.

Status in 1996:

High bandwidth detectors (many 10's GHz) existed.

No technology existed to record multi-GHz for 10s of μ s.

SMF core at 532 nm is 5μ m. Very difficult to launch high power lasers into such small cores.

Fiber lasers did not exist.



We applied for some research funding (LDRD) in 1997

LDRD-ER Proposal

Photonic Doppler Velocimetry

May 14, 1997



Principal Investigator

Ted Strand - DNT

Co-Investigators

Mark Lowry - P&ST
Ron Haigh - DSED
Rick Ratowsky - DSED
Paul Sargis - DSED

Goal


Long term (3-5 years):

- Develop 100+ channel, compact 3-D velocimetry diagnostic for time-resolved, full 3-D HE experiments.

Vision:

- A pin dome diagnostic with time resolved velocity profiles on every data channel

FY98 and FY99



Nevada National Security Site


Managed and Operated by National Security Technologies, LLC

We emphasized the advantages of alternative methods

Motivation Velocimetry Using High-Bandwidth Techniques




Fabry-Perot



This is the best way we know
High-quality data
Robust against multiple velocities
But....
Large physical size
Labor intensive
Expensive

Photonics Technology



This has many advantages
Small physical size
Inexpensive components
Large number of channels
Low manpower
But....
Always unambiguous data?

-HighBandVel-08



Our approach to measure beat frequency at 532 nm:
(LDRD)

Determine the limits of maintaining some level
of coherence in multi-mode fibers.

Convert frequency to some other parameter
that is more easily measured with standard digitizers.



Nevada National Security Site

Managed and Operated by National Security Technologies, LLC



There were some published results on maintaining coherence in multi-mode fiber (LDRD)




Fig. 1. Laser Doppler velocimetry experiment for measuring the speed of a rotating wheel.




Fig. 4. Heterodyne measurement between two CO₂ laser beams, through a split silver halide fiber.




Fig. 3. Heterodyne signal, as measured in the spectrum analyzer.


CO₂ lasers at 10.6 μm
Katzir, et al, Opt Eng 23(4), 1984

Our group did some work to reproduce those results (LDRD)

Recent experiments verified heterodyne detection using multimode waveguides



Modulation depths of over 10% (using a kilometer of 50 μ m diameter multimode fiber with a multimode fiber coupler) have been achieved when beating two lasers.




Very little theoretical and experimental background to validate concept and governing physics; some results at 10 μ m in the literature.

Heterodyne detection using multimode waveguide Y-couplers,
J. Salzman, U. Sivan, E. Kapon, and A. Katzir, Applied Optics 22(24),
3931-3934 (1983)



Convert RF to amplitude (LDRD):



Can measure resulting waveforms at slower digitizing rates,
But--

Hard to characterize for, say, 1% measurements.

Need multiple bandpass filters for large velocity range.


Multiple detectors per probe.

Can make only single-frequency measurements.

Requires homodyne with constant beat amplitude.

Hard to implement above 1 GHz.

Convert RF to phase (LDRD):



Can measure resulting waveforms at slower digitizing rates,
But--

Need to characterize for, say, 1% measurements.

Need multiple delay circuits for large velocity range.

Multiple detectors per probe.

Can make only single-frequency measurements.

Frequencies < 500 MHz requires up-conversion.

We built this box and tested with mixed results—
good in the lab but not so good on tests.

By 2000, we realized we had requirements for 2 frequency regimes on sub-critical exp'ts:

Low frequencies: use direct record method

CDU-driven flyer foils

Asay foils

Beat frequency is low enough to record directly with standard digitizers

High frequencies: use phase discriminator method

HE-driven experiments

Gas gun experiments





Nevada National Security Site


Managed and Operated by National Security Technologies, LLC




We compared direct record PDV with Fabry-Perot (532nm)



Fabry-Perot Velocimetry



Photonic Doppler Velocimetry



We observed polarization effects with direct record method





Figure 4. Raw data from niobium foil experiment: (a) S polarization, (b) P polarization.







Figure 5. Processed data from niobium foil experiment: (a) S polarization, (b) P polarization.

The phase discriminator method was noisy on shots (1064nm)




Comparison of Fabry-Perot and Photonic Velocimetry Data on Site 300 Shot



By 2002, we had to admit that MM fiber was giving us low SNR.

Modal dispersion in step-index fiber spreads information.



information
at one instant
in time here

gets spread out
in time over here

If the modal dispersion = one beat period,
then the contrast goes to zero!!



We finally admit defeat with MM fiber.

PDV: 532 nm system


There are problems with multi-mode fiber



For $\lambda = 532 \text{ nm}$ and $v = 1 \text{ mm}/\mu\text{s}$: There were 2 issues to overcome:
 $f = 5.6 \times 10^{14} \text{ Hz}$ 1) How to measure 4 GHz for $30 \mu\text{s}$?
 $2(v/c)f = 3.8 \text{ GHz}$ 2) Beat amplitude?

Paul Sargis solved the first issue fairly quickly
 Use phase discriminators to convert high frequency to phase information


But, the beat amplitude problem was harder to solve
 Modal dispersion in the step-index fiber reduced the signal contrast
 At $1 \text{ mm}/\mu\text{s}$, the beat period is 0.26 ns
 At U1a with 80 m of step index fiber, the modal dispersion is 2.2 ns



With graded-index fiber, the modal dispersion is 9 ps




But, suppose we use graded index fiber?



I had just finished building a probe with GI return fiber...

Tony walked into my office with some literature on a device called a “circulator”.

He said “Suppose we hook up a laser here, and put a probe here, and a detector here...will that work??”



“And, by the way, we would need to switch from 532 nm to 1550 nm.”

Consequences of going from 532 nm to 1550 nm:

1550 nm is not visible—need some type
of visible alignment laser

Parts for 1550 nm are commercially available

Multimode fiber (100 μm core) to single mode fiber (9 μm core)


Spot size goes from 1 mm dia to 100 μm with standard probe
Higher spatial and temporal resolution, surface roughness?

Single-fiber probe allows much more flexibility

Final configuration will be much smaller and cheaper



Where should we put the reference source??



We decided to put the reference source at the fiber endface inside the probe:

- Simple system—very few knobs


- Doppler-shifted and reference follow essentially the same path

But

- Less flexibility in reference level

- Need to calculate what the surface return might be before ordering probes

Power Budget for 1550 nm PDV with circulator:




$$?? \text{ W} \times 0.85 \times 0.99 \times (1e-4 + 1e-4) \times 0.99 \times 0.85 = 60 \mu\text{W}$$

$$?? = 424 \text{ mW} !!$$

(Compared to 50 – 100 W per probe for Fabry-Perot)

Calculate Signal from Probe



$$60 \mu\text{W} \times 3500 \text{ V/W} = 210 \text{ mV total}$$

Half = 105 mV from surface

Half = 105 mV from reference

Calculate Beat Amplitude

$$I(t) = I_0 + I_d + \sqrt{I_0 I_d} \sin[f_b(t) + \phi]$$

beat amplitude

beat frequency

$I(t)$ = total signal

I_0 = reference signal

I_d = doppler-shifted signal

$f_b(t)$ = beat frequency

ϕ = phase

$$I_{\text{beat}} = \text{sqrt}(105\text{mV} \times 105\text{mV}) = 105 \text{ mV}$$

should be a useable signal—let's start checking it out



Tony started gathering up parts:

30 mW linearly polarized fiber-coupled laser diode

1550 nm single mode fiber

Polarized Circulator

Focuser and collimator probes from DSA

Thorlabs detector

Woofers speaker

High Voltage spark gap bridge wire (safety people loved it)




Nevada National Security Site

Managed and Operated by National Security Technologies, LLC




Tony set a basic system up in the lab



We had a very difficult time maintaining good beat amplitude.

The slightest touch would make the signal change wildly.


We realized we had more than one reference source



The reflections from the various flat connectors were competing with the reference from inside the probe.

Different sources easily go in and out of phase as the fibers move.

Changed to angled connectors between circulator and probe



This helped enough that we could maintain fairly good beat amplitudes.
→ Keep investigating this method.

We realized from our previous work that we needed to go to a polarization-insensitive system.

By this time, fiber lasers had become available.
We bought a 1-watt unpolarized model.

We bought polarization insensitive circulators.

We used angle polished connectors everywhere.

Things started working well enough to start making performance measurements in the lab.

Tony got busy...





Nevada National Security Site



Managed and Operated by National Security Technologies, LLC




Beat amplitude vs laser power is linear as expected.
(doppler-shifted signal equal to reference signal)



Beat signal vs ratio of reference to doppler-shifted light.
 Should peak at 1:1, but these are difficult measurements when the probes have large back reflection.



Beat Signal Amplitude and Optical Power on detector vs. Doppler/Ref Ratio



It was time to start looking for shots to field our new system on.

People were very reluctant to give us any useful real estate—edges of flanges, etc

Could not impact shot schedule

Poor geometry = poor data

This went on for quite a while

Finally, Leon Berzins arranged with Vlad Georgvich of LLNL to let us field our PDV on one of his shot series




Nevada National Security Site

Managed and Operated by National Security Technologies, LLC



Tony cobbled together a 3-channel system with a mixed bag of probes and we went to NTS

Our 1st shot with the PDV was at the BEEF bunker (NTS) on March 10, 2003.




1 W laser


3 channels
(no knobs!)

We borrowed
digitizer channels
from the bunker


We barely had enough parts for 3 channels




The data was less than perfect...



Looks good!



Anything here??




Electrical noise here




But at least we got something!

Probe 1
115 mm




Still looks good!

Probe 2
3 mm
collimator



Still not sure


Probe 3
4.5 mm



Definitely have some data!



I did the 1st analysis via peak-finding method using Excel spreadsheets



Excel can handle only 50,000 rows of data, so I needed to split the data file among 10 spreadsheets.




I applied different amounts of smoothing until I found only 1 peak per half cycle.

Then I gathered up all the times at which the peaks occurred, and calculated the velocity averaged over the half cycles.

This took about 2 days per probe.



Not too bad for our 1st try on a real shot



By mid-2003, fiber lasers were getting more powerful:
2W models were available.

Agilent came out with the first digitizers that could
record at 20GS/s and 6 GHz for 50 μ s !!

We had shown that the direct record method worked well.
Abandoned the phase discriminator method.

We still needed a backup system for Accordion.

Bechtel/Nevada bought first two Agilents.

(Accordion was eventually cancelled.)



Bill Kuhlow of Bechtel/Nevada wrote the first sliding Fourier transform code for PDV:

Used MatLab

Two parts:

- Batch mode to calculate spectrograms

- Interactive mode to define regions of interest and extract

Fixed 50% overlap

User-friendly for defining regions of interest




Nevada National Security Site

Managed and Operated by National Security Technologies, LLC



We designed the modern PDV system with 4 channels to match the number of inputs on the digitizers.



Rev. Sci. Instrum. **77**, 083108 (2006)

Conclusions

The development of the PDV was driven by programmatic requirements (SCE).

LDRD funding was instrumental in getting the process started.

Using multi-mode fibers did not work out (modal dispersion).

Converting the beat frequency to a more easily measured quantity was difficult.

As we were working the problem, the technology advanced to the point that recording the beat frequency directly with single mode optics became possible.

At LLNL, the Fabry-Perot system was abandoned in favor of the PDV.

