


# Development of a 1064 nm PDV system



*Exceptional  
service  
in the  
national  
interest*

T. Ao and D. H. Dolan

Sandia National Laboratories, Albuquerque, NM

Photonic Doppler Velocimetry Workshop 2016  
Livermore, CA, June 7-9, 2016




Sandia National Laboratories is a multi-program laboratory managed and operated by Sandia Corporation, a wholly owned subsidiary of Lockheed Martin Corporation, for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-AC04-94AL85000.

# Acknowledgements

- NSTec: Sheri Payne and Brian Esquibel
- SNL DICE facility: Randy Hickman, Nicole Cofer, Keith Hodge


## Outline

- Background and motivation
- Design and implementation
- Dynamic compression test








# Background

- PDV uses readily available fiber-based components ( $\lambda_0 = 1550$  nm)
  - Infrared lasers
  - Circulator
  - Fiber coupler
  - Fast infrared detector
  - GHz digitizer
- Beat frequency proportional to velocity:  $f = \frac{2v}{\lambda_0}$ 
  - For 1550 nm:
    - 1 GHz  $\rightarrow$  0.775 km/s
    - 1 km/s  $\rightarrow$  1.29 GHz
  - For 1064 nm:
    - 1 GHz  $\rightarrow$  0.532 km/s
    - 1 km/s  $\rightarrow$  1.88 GHz





# Motivation

- Absorption of near infrared light in liquids due to vibrational overtones





# Design of 1064 nm PDV system

- Lasers
  - Reference: NKT Photonics Koheras Adjustik Y10 Standard (10 mW)
  - Target: NKT Photonics Koheras Adjustik Y10 Power (100 mW)
- Fiber components
  - Circulator
  - 2x2 coupler
  - Probe: GRIN collimator and lens
  - SM980 fiber/patch cables
- Detectors
  - Optilab high-speed receiver, 20 GHz
  - Thorlabs power meter
- Digitizer
  - Keysight scope, 8 GHz, 20 GSa/s
  - Tektronix scope, 6 GHz, 25 GSa/s






# Spinner target test setup






# Static spinner target

- Diffuse reflector: Reference = 0 dBm; Target = -16 dBm




# Spinning target

- Measured 8.0 MHz shift in beat frequency; 4.2 m/s velocity




# Dynamic compression test setup on DICE gas gun

- Quartz sample sandwiched between sapphire impactor and sapphire window
- Direct comparison between 1550 nm and 1064 nm PDV systems



Top View




1550 nm PDV probe

1064 nm PDV probe

Rear View


# 1550 nm PDV static

- Reference = 0 dBm; Target = -10 dBm






# 1064 nm PDV static (weak laser issues)



- Reference = -14 dBm; Target = -30 dBm



# 1550 nm PDV absolute frequency





# 1064 nm PDV absolute frequency



# Comparison of velocity histories

- C-cut sapphire index of refraction and window correction
  - 532 nm:  $n_0 = 1.772$ ,  $a = 1.785$ ; D. B. Hayes, *et al.*, J. Appl. Phys, **94**, 2331 (2003)
  - 1064 nm:  $n_0 = 1.755$ ,  $a = 1.738$
  - 1550 nm:  $n_0 = 1.746$ ,  $a = 1.728$ ; B. J. Jensen, *et al.*, J. Appl. Phys. **101**, 013523 (2007)



# Summary

- A 1064 nm PDV system was designed, implemented and tested on a dynamic compression experiment
  - Extracted velocity history agreed with 1550 nm PDV results
  - Obtained a 1064 nm window correction for sapphire
- Compared to 1550 nm hardware, 1064 nm hardware:
  - Lasers slightly less stable
  - Fiber components slightly more lossy
  - Parts are less available and/or more expensive
- Need to fix 1064 nm laser
  - Repeat experiment to get better 1064/1550 PDV comparison

